

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-1408:107 Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: Signal Communications Corp., 4 Wheeling Avenue, Woburn, MA 01801
Contact: Nadim Farhat (781) 933-0998

DESIGN: Models SG-32AX, SG-32B, SG-32PS, SG-32S, SG-33B, SG-33S, SG-33AX, SG-34B, SG-34S, SG-34AX, and SG-34PS, followed by H (hex lock) or K (key lock), followed by suffix 1 (push bar) or 2 (no push bar) noncoded manual pull stations. Models SG-32PS and SG-33PS do not have suffix -1 or -2. Suitable for outdoor use when installed with Model SGB-32C back box. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 30 VDC

INSTALLATION: In accordance with listee's printed installation, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as manual pull stations for use with separately listed and compatible fire alarm control units.

*Rev. 11-27-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 15, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager